

DSC 4181

DANIEL'S SERVICE CO., INC.
16375 W. CRESCENT DOVER RD.
CRESCENT, OK 73028
(405) 969-3066
E-mail: Dscinc06@aol.com ST. LIC. # 90930

DATE ORDERED: 12/15/20
DATE SCHEDULED: / /
E-MAIL: / /
PHONE: / /
NAME: Kenny Nealis
STREET: 3009 S. Council Rd
CITY: Cashew OK STATE: ZIP: 73016
WK OR CELL: 620-6848
MAKE: MODEL: SERIAL NUMBER:
JOB LOCATION: 3009 S. Council Rd, Cashew OK
DESCRIPTION OF WORK: SERVICE

WARRANTY
 CONTRACT
 SERVICE CONTRACT
 NORMAL
 RES COMM.

QUANTITY	ITEM OR PART DESCRIPTION	PRICE	AMOUNT
	Replace Heat Pump Compressor Model No. 7R49KSE-PFK-800 Serial No. 19GA4158L Bi-Flow Line Drier 10 lbs R-22 Refrigerant	156300	156300
	RETROFIT APPLIED		
	REFRIGERANT ADDED		
	TOTAL PARTS		

TECH #1: / / HRS. @ /HR. = / OVERTIME
TECH #2: / / HRS. @ /HR. = / OVERTIME
TECHNICIAN SIGNATURE: [Signature]
CERT. #:

TOTAL OTHER CHARGES: \$156300

TERMS: DUE UPON COMPLETION

I HAVE THE AUTHORITY TO ORDER THE ABOVE WORK AND DO SO ORDER AS OUTLINED ABOVE. IT IS AGREED THAT THE SELLER WILL RETAIN TITLE TO ANY EQUIPMENT OR MATERIAL FURNISHED UNTIL FINAL & COMPLETE PAYMENT IS MADE, AND IF SETTLEMENT IS NOT MADE AS AGREED, THE SELLER SHALL HAVE THE RIGHT TO REMOVE SAME AND THE SELLER WILL BE HELD HARMLESS FOR ANY DAMAGES RESULTING FROM THE REMOVAL THEREOF.

OWNER'S INITIALS: /

- CHECK LIST**
- SUCTON PSI
 - HEAD PSI
 - VOLTS AMPS
 - ELECTRICAL CONNECTIONS
 - CONTACTOR TIGHT & CLEAN Y/N
 - OIL LEVEL & CONDITION
 - BURN OUT
 - CONDENSER COIL
 - CLEAN COIL & CHECK FIN COND.
 - ENT. °F LVG °F
 - REFRIGERANT
 - LEAK °F CHARGE
 - FAN AND MOTOR
 - VOLTS AMPS
 - ELECTRICAL CONNECTIONS
 - CONTACTS TIGHT & CLEAN
 - FAN PULLEYS (ADJUST BELT)
 - CHECK LUBE BEARINGS & MOTOR
 - OFM
 - EVAPORATOR COIL
 - CLEAN COIL & CHECK FIN
 - ENT DB °F LVG DB °F
 - ENT WB °F LVG WB °F
 - CONDENSATE AREAS
 - INSPECT & CLEAN DRAIN PAN
 - CLEAN & CLEAN DRAIN
 - AIR FILTERS
 - CLEANED REPLACED
 - FILTER SIZE
 - HEATING ASSY.
 - BURNER & HEAT EXCHANGER
 - FUEL SUPPLY & PRESSURE
 - PILOT ASSEMBLY
 - FLAME ADJUSTMENT
 - PRIMARY RELAY & FLUE
 - FAN & LIMIT SWITCH OPER.
 - BLOWER ASSEMBLY
 - RV VALVE
 - STRIP HEAT
 - DEFROST CYCLE
 - ELECTRICAL COMPT'S.
 - RELAYS CONTACTORS
 - OVERLOAD PRESS. SWITCH
 - THERMOSTAT
 - O.K. REPLACE
 - RELOCATE
- TRAVEL TIME: / /
- MILEAGE: /
- ENDING: / /
- START: / /
- TOTAL MILES: /
- X /HR. #

ABOVE ORDERED WORK HAS BEEN COMPLETED AND I ACKNOWLEDGE RECEIPT OF MY COPY. DATE: / /